



Pat Quinn, Governor
LaMar Hasbrouck, MD, MPH, Director

525-535 West Jefferson Street • Springfield, Illinois 62761-0001 • www.idph.state.il.us

September 30, 2013

Mr. Cole Perkins
Perma-Liner Industries LLC.
13000 Automobile Blvd, Suite 300
Clearwater, Florida 33762

RE: Lateral Cured in place Pipe Lining System

Mr. Perkins,

In response to your presentation of Perma-Liner Industries Lateral Cured in Place pipe lining system before the Illinois Plumbing Code Advisory Council and staff of Illinois Department of Public Health on September 23, 2013, please note the following.

The Illinois Plumbing Code Advisory Council has reviewed your presentation and the information you provided. By unanimous decision of those individuals in attendance the use of Perma-Liner Lateral Cured in Place pipe lining system is approved for use in Illinois limited to building sewer main connection, not to exceed five feet beyond building drain connection.

If you have any questions or concerns regarding this matter, please contact the Illinois Department of Public Health, Attn: Plumbing Program, 525 West Jefferson Street 3rd FL. Springfield, Illinois 62761, telephone 217- 524-0791.

Sincerely,

A handwritten signature in black ink, appearing to read "Frank W. Shimkus".

Frank W. Shimkus
Plumbing Consultant
IDPH Plumbing Program

Improving public health, one community at a time

printed on recycled paper